



# Hurricane Harvey Slams Houston





# Hurricane Harvey Slams Houston



CFISD Facilities, Maintenance and Operations Teams worked hard to assess the damage caused by the heavy rain and flood water our school district received. A number of campuses sustained minor roof and water damage, but one of our campuses, Moore Elementary School, was not so fortunate. Cypress Creek and Little Cypress Creek overflowed in multiple locations, resulting in approximately 18" of water in Moore Elementary School.




**MOORE  
ELEMENTARY  
SCHOOL**

Technology was asked to be onsite at Moore ES on Thursday, August 31, 2017 to assess the damage. Pictured left are Technology Services' staff members Frank Adian and Jennifer Miller.






# Hurricane Harvey Slams Houston



Due to significant damage at Moore ES, the decision was made to relocate Moore to the old Matzke Elementary School building for at least the fall semester until renovations are complete.



# Hurricane Harvey Slams Houston



Anna Senties represented the Enterprise Communications Network team during the campus evaluation. Pictured above are network components that had been under water in the MDF and IDF network closets.





# Hurricane Harvey Slams Houston



## Anna Discovered the Following:

1. Water entered 2 of 3 closets (3<sup>rd</sup> closet mounted high).
2. All UPS units were damaged.
3. VoIP ATA router might have been damaged (mounted low on rack and hard to tell).
4. No network switches were sitting in water, but need to evaluate the hardware.

## Next Steps:

1. Will need assistance collecting switches from racks and relocate to ISC. Anna gave her cell to the GC and he will let her know the best time to remove switches from the closets.
2. We still have Old Matzke network equipment on site.
3. ECN will reconfigure Old Matzke equipment as Moore ES.
4. Wireless Access Points will need to be removed during renovation.